

PROPOSAL STATISTICS

DENSITY

14,995 SF SITE AREA (120'x124.9')
±173,995 SF OF TOTAL GROSS FLOOR AREA
±10.28 FSR

HEIGHT

35 STOREYS
± 348'-4" ABOVE BASE HEIGHT

RESIDENTIAL

100 - 1 BEDROOM/STUDIO SUITES
43 - 2 BEDROOM SUITES
16 - 3 BEDROOM SUITES
159 SUITES TOTAL

PARKING

68 REGULAR STALLS
15 SMALL CAR STALLS
11 VISITOR CAR STALLS
5 ACCESSIBLE STALLS
4 REGULAR CULTURAL AMENITY STALLS
2 ACCESSIBLE CULTURAL AMENITY STALLS

2 CLASS 'A' RESIDENTIAL LOADING (LOCATED AT GRADE)
1 CLASS 'B' RESIDENTIAL LOADING (SHARED WITH CULTURAL AMENITY)

338 CLASS 'A' BICYCLE PARKING STALLS
7 CLASS 'A' CULTURAL AMENITY BICYCLE PARKING STALLS
12 CLASS 'B' BICYCLE PARKING STALLS

RESIDENTIAL AMENITY

± 2,207 SF RESIDENTIAL AMENITY SPACE ON LEVEL 2
± 1,040 SF RESIDENTIAL AMENITY SPACE (INDOOR) ON LEVEL 6
± 1,850 SF RESIDENTIAL AMENITY DECK (OUTDOOR) ON LEVEL 6

PUBLIC BENEFITS


± 10,531 SF PUBLIC CULTURAL AMENITY ON LEVEL 1, MEZZANINE, & LEVEL 2



CITY CONTEXT



SITE CONTEXT



SITE CONTEXT PHOTOS

SITE



HORNBY STREET (VIEW TO SOUTHEAST, TOWARD SITE)

SITE




HORNBY AND DRAKE INTERSECTION (VIEW TO SOUTHEAST, TOWARD SITE)

SITE




HORNBY AND DRAKE INTERSECTION (VIEW TO NORTH, TOWARD BURRARD GATEWAY)

SITE




LANE (VIEW TO NORTHWEST, TOWARD SITE FROM REAR LANE)

CONTEXT PLAN



SITE PLAN



OUR PROPOSAL



HORNBY & DRAKE ST. VIEW

1290 HORNBY STREET LTD.

OUR PROPOSAL




HORNBY STREET (MAIN CULTURAL AMENITY ENTRANCE)




DRAKE STREET (RESIDENTIAL ENTRANCE)



LANE ENTRANCE (LOADING AND PARKADE ENTRANCE)






PLANS



PLANS




LEVEL 2 PLAN
1/8"=1'-0"


-  CULTURAL AMENITY
 RESIDENTIAL AMENITY
 RESIDENTIAL




PLANS




⊗ LEVEL 8-9 PLAN




LEVEL 7 PLAN




LEVEL 6 PLAN



LEVEL 5 PLAN



LEVEL 4 PLAN




LEVEL 3 PLAN

RESIDENTIAL
RESIDENTIAL AMENITY




1290 HORNBY STREET LTD.


PLANS




⊗ LEVEL 30 PLAN




LEVEL 25-29 PLAN




LEVEL 28 PLAN



LEVEL 25-27 PLAN



LEVEL 15-24 PLAN




LEVEL 10-14 PLAN

RESIDENTIAL




1290 HORNBY STREET LTD.


PLANS




⊗ ROOF PLAN




LEVEL 35 PLAN




LEVEL 34 PLAN



LEVEL 33 PLAN



LEVEL 32 PLAN




LEVEL 31 PLAN


RESIDENTIAL




PLANS




⊗ LEVEL P1 PLAN




LEVEL P2 PLAN




LEVEL P3 PLAN



LEVEL P4 PLAN




LEVEL P5 PLAN




LEVEL P6 PLAN




STREET ELEVATION IN CONTEXT



HORNBY STREET ELEVATION




DRAKE STREET ELEVATION




PUBLIC BENEFITS

As part of the City's *Community Amenity Contributions (CAC) through Rezoning*s policy, 1290 Hornby St. proposes a $\pm 10,531\text{ft}^2$ Cultural Amenity to accommodate artist production and presentation space.




CULTURAL AMENITY
LEVEL 1 & MEZZANINE



CULTURAL AMENITY
LEVEL 2



INTERIOR VIEW AT THE MAIN ENTRANCE




VIEW OF DOUBLE HEIGHT SPACE




ARTISTIC RENDERING OF THE 'TATE' ARTIST STUDIO'S
(1283 HOWE ST.)

The proposal of artist production and presentation spaces aims to capitalize on the potential synergy between 1290 Hornby St. and the new artist studio's located across the lane (1283 Howe St.). Pedestrian access from the Cultural Amenity to the lane will facilitate ease of movement between these public spaces.




1290 HORNBY STREET LTD.

CULTURAL AMENITY



CULTURAL AMENITY
LEVEL 1 & MEZZANINE



CULTURAL AMENITY
LEVEL 2

EXTENT OF AMENITY SPACE



CULTURAL AMENITY




INTERIOR VIEW AT THE MAIN ENTRANCE LOOKING TOWARD LANE



INTERIOR VIEW NEAR MAIN ENTRANCE LOOKING TOWARD DRAKE STREET



INTERIOR VIEW NEAR CORNER OF HORNBY AND DRAKE




1290 HORNBY STREET LTD.


CULTURAL AMENITY



INTERIOR VIEW NEAR MAIN ENTRANCE LOOKING TOWARD MEZZANINE



INTERIOR VIEW OF LEVEL 2



VIEW OF DOUBLE HEIGHT SPACE



1290 HORNBY STREET LTD.


HORNBY ST. ELEVATION



DRAKE ST. ELEVATION




LANE ELEVATION



SIDE YARD ELEVATION



SECTION




SECTION




SECTION 1/A4.04


CULTURAL AMENITY
RESIDENTIAL




SHADOW STUDY




March 20th, 10:00 AM




March 20th, 11:00 AM



March 20th, 12:00 PM




March 20th, 2:00 PM



1290 HORNBY STREET LTD.







BURRARD GATEWAY SHADOW STUDY



1 SHADOW STUDY ON BURRARD GATEWAY PODIUM
SCALE: 1/16"=1'-0"

1290 HORNBY STREET LTD.

VIEW ANALYSIS



PUBLIC REALM




PUBLIC REALM



PUBLIC REALM






LEVEL 1 LANDSCAPE PLAN

H O R N B Y S T R E E T



DRAKE STREET

Refer to Sheet L1.0 for Considered Plant List




LANE


 LEVEL 6 LANDSCAPE PLAN

1290 HORNBY STREET LTD.

STREETSCAPE





1 Section through Streetscape at Drake Street
L 1.1 Scale: 1/4" = 1'=0"



2 Section through Vehicle Drop-Off Area at Gallery Entry
L 1.1 Scale: 1/4" = 1'=0"



LANDSCAPE



SUSTAINABLE DESIGN

SUSTAINABLE DESIGN STRATEGY

As a part of the Rezoning Application package, the following Sustainable Design Strategy has been developed to provide confirmation the project design submitted is on target to meet the requirements as dictated by the Green Buildings Policy for Rezoning 2016, option B. Low Emissions Green Building, effective May 1, 2017.

The following narrative includes preliminary strategies explored by the design team, with the aim to achieve the various requirements of the Low Emissions Green Building pathway, along with all required supporting evidence at this stage, as listed:

- Item B.2: Brief summary of strategies and measures to achieve performance limits for energy use, heat loss, and greenhouse gas emissions, including:
 - Preliminary Zero Emissions Building Plan (ZEBP) Energy Checklist, completed by the project energy modeller, showing that the project meets the performance limits for energy use (TEUI), heat loss (TEDI), and greenhouse gas emissions (GHGI), together with key inputs;
 - 2-4 page summary of detailed energy model inputs for detailed and/or 3rd party review.
- Item B.6.2: Preliminary embodied emissions calculations, and a description of specific measures that will be explored during design to reduce embodied emissions;
- Item B.10: The site IRMP, describing the chosen strategies and green and grey infrastructure measures included in the landscape and building design. The IRMP describes:
 - How these measures contribute to the city-wide IRMP targets for water volume reduction and quality treatment, and
 - Include preliminary site and volume calculations to compare site performance to the City-wide targets;
 - Landscape/Architectural Site Plans highlighting the green and grey infrastructure measures described in the site IRMP as also provided.
- A commitment by the owner to meet the requirements of the Green Buildings Policy for Rezoning with documentation to be submitted at a later project phase, including:
 - B.3: design, build, and test to meet an airtightness target of 2.0 L/s/m² @ 75 Pa;
 - B.4: complete an enhanced commissioning process;
 - B.5: design and build to include building metering and sub-metering of energy, and to enter into agreement on energy reporting, including assistance for building future owners;
 - B.6.1: complete refrigerant emissions calculations;
 - B.7: design and build a direct ventilation system;
 - B.8: design and build with low-emitting materials;
 - B.9: test indoor air quality prior to occupancy;
 - B.11: design and build a resilient potable water access point.

ENERGY MODEL INPUTS

1290 Hornby Street - LCES Type 2a: Utility-Owned On-Site LCES City of Vancouver Rezoning Energy Modeling Input Summary Table

Design Model Characteristics																													
General																													
Location	Vancouver, BC																												
Simulation Weather File	Vancouver 2016 CWEC																												
Climate Zone	ASHRAE Climate Zone 5C																												
Modeling Software	eQUEST 3.64																												
Building Area	Above grade area: 164,000 ft²																												
Hours of Operation	Based on ENERGY MODELLING GUIDELINES section 2.1 Schedules																												
Envelope Performance																													
Overall Roof U-value (BTU/h-ft²-F)	U-0.033 (R-30)																												
Overall Wall U-value (BTU/h-ft²-F)	Solid wall: U-0.064 (R-15.6) (81% of total vertical envelope) Spandrel: U-0.25 (R-4) (12% of total vertical envelope) Thermally Broken Slab Projection balcony: =0.25 BTU/h-ft²-F Overall U-0.10 (R-10)																												
Percentage Glazing	27%																												
Overall Glass U-value including frame (BTU/h-ft²-F), and Solar Heat Gain Coefficient (SHGC)	U-0.35 (fixed), U-0.40 (operable) SHGC-0.35																												
Floor above parkade U-value (BTU/h-ft²-F)	U-0.048 (R-20)																												
Infiltration	Modeled infiltration: 0.2 L/s/m² (0.038 cfm/ft²) as per CoV ENERGY MODELLING GUIDELINES 2.4.1																												
Internal Loads																													
Occupancy	Residential: People = no. bedrooms + 1; Studio = 1 person Other spaces as per NECB 2011 (based on CoV ENERGY MODELLING GUIDELINE 2.2)																												
Lighting Power Density (LPD) (W/m²)	<table><tr><th>NECB Space by Space Method</th><th>Proposed Lighting Power Density (W/m²)</th></tr><tr><td>Amenity (Lounge/Recreation)</td><td>0.97</td></tr><tr><td>Amenity Cultural (Convention centre-Exhibit space)</td><td>1.45</td></tr><tr><td>Studio/gallery (Museum/general exhibition)</td><td>1.05</td></tr><tr><td>Corridor <2.4</td><td>0.78</td></tr><tr><td>Electrical/Mechanical</td><td>1.25</td></tr><tr><td>Lobby for elevator</td><td>0.64</td></tr><tr><td>Lobby other</td><td>0.90</td></tr><tr><td>Office</td><td>1.11</td></tr><tr><td>Parking garage</td><td>0.13</td></tr><tr><td>Residential suite</td><td>0.46</td></tr><tr><td>Restroom</td><td>0.98</td></tr><tr><td>Stairway</td><td>0.66</td></tr><tr><td>Storage</td><td>0.63</td></tr></table>	NECB Space by Space Method	Proposed Lighting Power Density (W/m²)	Amenity (Lounge/Recreation)	0.97	Amenity Cultural (Convention centre-Exhibit space)	1.45	Studio/gallery (Museum/general exhibition)	1.05	Corridor <2.4	0.78	Electrical/Mechanical	1.25	Lobby for elevator	0.64	Lobby other	0.90	Office	1.11	Parking garage	0.13	Residential suite	0.46	Restroom	0.98	Stairway	0.66	Storage	0.63
NECB Space by Space Method	Proposed Lighting Power Density (W/m²)																												
Amenity (Lounge/Recreation)	0.97																												
Amenity Cultural (Convention centre-Exhibit space)	1.45																												
Studio/gallery (Museum/general exhibition)	1.05																												
Corridor <2.4	0.78																												
Electrical/Mechanical	1.25																												
Lobby for elevator	0.64																												
Lobby other	0.90																												
Office	1.11																												
Parking garage	0.13																												
Residential suite	0.46																												
Restroom	0.98																												
Stairway	0.66																												
Storage	0.63																												
Exterior Lighting (kW)	All LPD as per NECB 2011, except parking: 0.13 W/m² 1.34 kW																												
Plug-Loads	Residential: 0.464 W/m² Electrical/Mechanical, Storage, Restroom: 0.093 W/m² Office: 0.697 W/m² Lobby, Lobby for elevator, Amenity: 0.093 W/m²																												
Process Loads	Amenity cultural, Studio, Gallery: 0.232 W/m² Parking, stairs, corridor: 0 W/m² (Based on CoV ENERGY MODELLING GUIDELINES) 2 lower elevators @ 3 kW each 3 elevators at L1 @ 3 kW each 1 elevator at PH @ 3 kW each (Based on CoV ENERGY MODELLING GUIDELINES) Main transformer room: 40 kW (assumption) Other electrical rooms: 5 kW (assumption)																												
Domestic Hot Water Consumption	Residential: 0.025 gpm/person with 30% reduction (low flow fixture) (Based on ENERGY MODELLING GUIDELINES section 2.2.1 Residential Suites)																												
Mechanical Systems																													
Indoor Design Temperature for Conditioned Areas	Based on ENERGY MODELLING GUIDELINES section 2.1 Schedules																												
System Description and Efficiency	Dwelling Units: Heating and cooling by air source VRF fan coil units and ventilation by individual ERV (Lifebreath ERV) <ul style="list-style-type: none">ERV fan power: 60 W (low speed), 154 W (high speed)Fan coil unit fan power: =0.20 W/cfmBathroom fan power: =13.6 W, fan hours of operation: 2 hr/dayKitchen hood fan power: =13.6 W, fan hours of operation: 2 hr/dayVentilation fans on continuously Podium Amenity: Heating and cooling by air source VRF fan coil units and ventilation through mechanical louvers (no heat recovery) <ul style="list-style-type: none">Fan coil unit fan power: =0.30 W/cfmDemand controlled ventilation in cultural amenity and common areas (CO₂ sensors)Fans run continuously during occupied hours and cycle on-off to meet the heating/cooling loads (OA off) Corridor: Roof-top air handler with electric heating (kept at 68°F) <ul style="list-style-type: none">Fan power: 0.30 W/cfm at 4,200 cfmHydronic heating coilVentilation fans on continuously Electrical rooms: <ul style="list-style-type: none">Fan power: =0.30 W/cfm Parkade: Parkade fan <ul style="list-style-type: none">Fan power: =0.20 W/cfmFan hours of operation: 4 hr/day																												
Minimum Ventilation Rates	Living areas: 0.35 air changes per hour but not less than 15 cfm per person Corridor pressurization: 25 cfm/door (kept at 68°F) (Outdoor air is calculated by ASHRAE 62-2001) Living areas: 7,630 cfm Corridor pressurization: 4,200 CFM (kept at 68°F) Amenities + Lobby +Gallery +Studio: 8,030 cfm																												
Ventilation Control	Demand controlled ventilation in cultural amenity and common areas (CO₂ sensors)																												
Heat Recovery	In-suite ERV (Lifebreath ERV) Sensible effectiveness: 83% at 49 cfm, 79% at 64 cfm																												
Central Plant																													
Heating Type and Efficiency	Air source VRF outdoor unit Efficiency: 4.2 heating COP																												
Cooling Type and Efficiency	Air source VRF outdoor unit Efficiency: 2.63 cooling COP																												
Domestic Water Heater and Efficiency	Condensing DHW heater Efficiency: 95% thermal efficiency																												
Pumps	N/A																												

LOW CARBON ENERGY SYSTEM

6.1 LCES Type 2a: Utility-Owned On-Site LCES

This type refers to a new utility-owned LCES located on-site within a development. Type 2a LCES must meet the following requirements:

(a) a qualified engineer must provide written verification that the LCES is designed to provide low carbon energy such that the development will meet the City's GHG limits;

(b) there must be evidence that a utility will purchase the LCES and supply long term energy service from the LCES to the development; and

(c) the utility must have demonstrated experience with other similar successful LCES.

Prior to the application for an occupancy permit, the developer must deliver evidence to the City's satisfaction that the LCES was successfully registered with the BCUC, and that the ownership of the LCES was, or will soon be, duly transferred to a utility.

ZERO EMISSIONS BUILDING PLAN ENERGY CHECKLIST

Zero Emissions Building Plan Energy Checklist

Please complete all fields that apply to the project, using information that represents the current stage of design. For fields that do not apply or for which there is no information yet, please enter "N/A".

Project Information (enter all that apply)

Project Address: 1290 Hornby Street, Vancouver, B.C.
Secondary Address:
Project Working Title: 1290 Hornby Street
POSSE File Name (City use only):
Gross Floor Area indicated on Arch. Drawings (m²): 15,242
Parkade Area (m²): 7,715

Building Information and Performance Limits

For building types with Performance Limits, enter this information in this section

Building Type(s)	Modelled Floor Area (m²)	Rezoning?	City-Recognized Low Carbon Energy System?	TEUI	TEDI	GHGI
Residential, 7+ stories (Group C except Hotel)	15,242	Yes	Yes	130	40	6
				0	0	0
				0	0	0
Total	15,242				40.0	

For other building types, create a baseline energy model to establish limits, and enter this information in this section

Building Type	Modelled Floor Area (m²)	Rezoning?	Energy (kWh)	Em. Factor	Emissions (kgCO2e)	TEUI	TEDI	GHGI
Enter Other Building Type Baseline Model Performance								
Total Annual Electricity Use			0.011	-	Baseline:	0	0	0
Total Annual Natural Gas Use			0.185	-	Target:	0	0	0
Total Annual District Energy Use			0.070	-				
Total			-	-				
Total Annual Heat Demand - for TEDI								

Total Modelled Floor Area (m²): 15,242
Modelled Floor Area within 5% of Gross Floor Area? Yes

Whole-Building Performance Limits


	TEUI	TEDI	GHGI
130.0	40.0	6.0	

Modelled Building Performance



Energy (kWh)	Fuel Type	Em. Factor	Emissions (kgCO2e)	TEUI	GHGI	
Interior Lighting	439,103	Electricity	0.011	4830.133	28.8	0.3
Exterior Lighting	4,989	Electricity	0.011	54.879	0.3	0.0
Heating	303,726	Electricity	0.011	4187.886	25.0	0.3
Cooling	161,297	Electricity	0.011	1774.267	10.6	0.1
Pumps	-	Electricity	0.011	0	0.0	0.0
Fans	288,365	Electricity	0.011	3172.015	18.9	0.2
Domestic Hot Water	301,454	Natural Gas	0.185	55769.01	19.8	3.7
Plug Loads	440,306	Electricity	0.011	4849.966	28.9	0.3
Elevator	45,223	Electricity	0.011	497.453	3.0	0.0
Total Annual Electricity Use	1,760,609	0.011	19,367			
Total Annual Natural Gas Use	301,454	0.185	55,769			
Total Annual District Energy Use	-	0.070	-			
Total	2,062,063		75.136			
Total Electricity Generated On-Site (kWh)		% of Use	0.0%			
Total Purchased Renewable Electricity (kWh)		% of Use	0.0%			
Total Purchased Renewable Natural Gas (kWh)		% of Use	0.0%			
Note: purchase renewables used to demonstrate compliance must be secured to satisfaction of AHJ						
Adjusted Electricity Emissions Factor (kgCO2e/kWh)	0.011					
Adjusted Natural Gas Emissions Factor (kgCO2e/kWh)	0.185					
Annual Heat Demand of portions with Perf. Limits (kWh)						
Total Annual Heat Demand - for TEDI (kWh)	656,894					
Total Annual Cooling Demand - for info only (kWh)	515,996	33.9 kWh/m²				
				135.3	43.1	4.9
Modelled Whole-Building Performance						
Corridor Pressurization Adjustment						
Heating Degree Days	2825					
Number of Suite Doors Pressurized	168					
Airflow for Pressurization per Door (L/s/door)	11.7986861					
Area of Corridors Pressurized (m²)	1268.169145					
Make-Up Air Fuel Type	Electricity					
Make-Up Air Emissions Factor	0.011					
Suite-level Metering for Space Heating	Yes					
Adjustments for Suite Submetering of Heating						
Note: select yes if the energy used for heating is metered at the suite level						
				8.9	8.9	0.1
Adjusted TEDI Performance of Portions with Limits						
				126.4	34.2	4.8
Modelled Inputs						
Modelled Above-Ground Wall Area (m²)	10,555					
Window-to-Wall Area Ratio (WWR)	27%					
Infiltration Rate (L/s/m²,adj)	0.2					
Wall Effective R-Value - incl. thermal bridging (m²K/W)	1.8	10.00 (R/hr°F/Btu)				
Roof Effective R-Value - incl. thermal bridging (m²K/W)	5.3	29.99 (R/hr°F/Btu)				
Average Window Effective U-Value (W/m²K)	2.1	0.37 (Btu/hr°F)				
Average Suite Occupant Density (m²/person)	27.57766365					
Average Suite Ventilation Rate (L/s/m²)	14.15942332					
Average HRV Effectiveness	79%					
Heating System Type (fuel, plant, distribution, etc.)	Air source VRF fan coil units					
Cooling System Type (fuel, plant, distribution, etc.)	Air source VRF fan coil units					
DHW System Type (fuel, plant, distribution, etc.)	Condensing DHW heater: 95% efficiency					
Modelled Information						
Modelled Name	Lam Pang					
These results have been created using the CoV Energy Modelling Guidelines version:	2					
Company	Integral Group					
Phone Number	604-687-1800					
Email	lpang@integralgroup.com					
ZEBP Energy Checklist v1.5 - 2018-07-27						

COMPARATIVE SHADOW STUDY


PROPOSED TOWER FORM




THEORETICAL TOWER FORM




PROPOSED TOWER FORM AT 348.3FT HEIGHT











THEORETICAL TOWER FORM AT 300FT HEIGHT



RESULTANT SUNPATH OF PROPOSED ASCENDING ROOF FORM



COMPARATIVE SHADOW STUDY



- FOOTPRINT OF PROPOSED AND THEORETICAL TOWER FORM
- SHADOWING FROM PROPOSED AND THEORETICAL TOWER FORM
- FOOTPRINT OF ADJACENT TOWERS



